
	DELHI JAL BOARD: GNCTD CENTRAL LABORATORY WTP WAZIRABAD, DELHI-54	
---	--	---


TEST REPORT			
Sample ID	Ref.No. D.J.B/DIQC/Wzd./2022/paid-103-104		
Location /Address of Sample	The Smarth School Facility Center, Gurudwara Road Dilshad Garden, Opp Pocket B-Park Delhi-95		
Name of Work	--		
Reference No.	TSSDG /2022-23/097	Ref. Letter Date	19.07.2022
Challan No.	138	Challan Date	21.07.2022
Sample Collection date	08.08.2022	Analysis date	09.08.2022
Any other Information	--	Reporting date	12.08.2022


TEST RESULTS


S.N.	Parameters	Unit	As per the IS 10500		1	2
			Desirable limit	Permissible limit		
1	Turbidity	NTU	1	5	1.56	0.72
2	pH Value	--	6.5-8.5	No relaxation	7.60	7.42
3	Colour	Pt-Co	5	15	Clear	Clear
4	Odour	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable
5	Electrical Conductivity	$\mu\text{s/cm}$	-	-	158	185
6	Total Dissolved Solids	Mg/l	500	2000	103	120
7	Total Alkalinity as CaCO_3	Mg/l	200	600	82	86
8	Total Hardness as CaCO_3	Mg/l	200	600	102	122
9	Calcium as Ca	Mg/l	75	200	25.6	32.8
10	Magnesium as Mg	Mg/l	30	100	9.12	9.60
11	Ammonical-Nitrogen	Mg/l	NIL	0.5	ND	ND
12	Nitrate	Mg/l	--	45	3.48	4.68
13	Chlorides as Cl	Mg/l	250	1000	18	22
14	Fluoride as F	Mg/l	1.0	1.5	0.22	0.27
15	Sulphate as SO_4	Mg/l	200	400	12.8	18.7
16	T. Iron	Mg/l	--	1.0	0.04	0.06
17	Residual Chlorine	Mg/l	0.2	1.0	0.50	ND
18	COLIFORM COUNT AT 37 ⁰ C	MPN/100 ml	Absent	--	0	0


.....End of Report.....

Remarks : : On the basis of above tested parameters, above water samples conform drinking Water Specification IS-10500 & can be considered fit for drinking purpose.


ACWA
Analyst
Central Laboratory
WTP Wazirabad


CHEMIST


Vice Principal
THE SMARTH SCHOOL
Facility Centre, Gurudwara Road
Dilshad Garden, Opp. Pocket B Park,
Delhi-110095, Phone-8287501871


A/CHEMIST

MUNICIPAL CORPORATION OF DELHI
OFFICE OF THE DY. HEALTH OFFICER
SHAHDARA NORTH ZONE

No. DHO/Shah (N)/2022/D-229

Dated: 30/7/22

SCHOOL INSPECTION REPORT

News

In reference to your application duly submitted in the office of undersigned vide diary no. 912, dated 09.07.2022, the inspection of "THE SAMARTH SCHOOL" at Facility Centre, Gurudwara Road, Dilshad Garden, Opp. Pocket B-Park, Delhi-110095 was carried out on 13.07.2022. During the inspection, it was found that the school is running under sanitary & hygienic conditions. Provision of latrines & urinals is sufficient according to the number of students.

In view of the above findings, undersigned is hereby pleased to grant "PROVISIONAL NO OBJECTION CERTIFICATE FROM HEALTH POINT OF VIEW" to the above-said school. This certificate is valid for a period of one year from the date of issue.

Chaudhary
Vice Principal
THE SAMARTH SCHOOL
Facility Centre, Gurudwara Road
Dilshad Garden, Opp. Pocket B Park,
Delhi-110095, Phone-8287501871

10
30/07/2022
Dy. Health Officer
Shahdara North Zone

Vice Principal
THE SAMARTH SCHOOL
Facility Centre, Gurudwara Road, Dilshad Garden
Opp. Pocket B-Park, Delhi-110095

